



Boulder Creek Fire Protection District

Kevin McClish, Chief
13230 Central Avenue
Boulder Creek, California 95006-9125

August 12, 2015

TO: PROSPECTIVE BIDDERS
SUBJECT: VOLUNTARY SEISMIC AND ADA STATION UPGRADES
BID OPENING: AUGUST 18, 2015

ADDENDUM NO. 2

The following shall modify the contract documents, and the work shall be accomplished with such modifications as if included within the original bid package. This addendum shall be attached to the specifications and submitted to owner at the bid date. This addendum contains an acknowledgment to be signed by the contractor. Failure to acknowledge the addendum or failure to attach same to the bid specifications for submittal to the Owner at the time of bidding may be grounds for rejection of the Bid.

- A. Repair (5) observation holes, approximately 2'x2', located in the Apparatus Bay. Also repair observation hole located in the ceiling of the Apparatus Bay along the steel beam. Repair using 5/8" Gypsum wallboard. Furr if required and finish to match existing surfaces.
- B. A Hazardous Materials Survey will be provided by the District.
- C. S1/Item 1 remove temporary wall located under beam in center of apparatus bay added to plans.
- D. Detail 7/S2 pocket door added to pantry entry, location of plywood shear wall clarified and one (1) shear wall deleted.
- E. General boxed note on S1 and S2 expanded to include other items including: relocating existing wiring and piping as required, remove and replace wall fixtures, removal and replacement of floor and ceiling finishes.
- F. Item 4, Detail 7/S2, Roof Wall Tie modified.
- G. S1 Special Inspection Summary expanded.
- H. Sheet A3 added.
- I. Streetlamps removed from A5.
- J. ADA ramps removed from sheets A2 and A5.
- K. Van Accessible parking changed on sheets A2 and A5.
- L. Remove electrical conduit and wing wall added to A2
- M. Added to A3 are bathroom floor and wall materials, tankless water heater notes and door trim notes.

All changes noted above are from revised drawings which will be uploaded to www.bcfcd.com on 8/13/15.

All other provisions of the contract documents remain the same.

If you have any questions regarding this addendum or other bid-related matters, please contact

Kevin McClish at (831) 338-7222.

Approved By:

Kevin McClish

Kevin McClish

Fire Chief

8/12/15

Date

Accepted By:

Contractor

Date

Title